

Belkin Bulldog Plus

Shutdown Management Software for Windows



User's Manual

Table of Contents

INTRODUCTION	5
Bulldog Plus features:	5
BULLDOG PLUS INSTALLATION	5
Bulldog Plus Setup:	6
BULLDOG PLUS SERVICE	7
BULLDOG PLUS MONITOR.....	9
NETWORKING	11
Operation Mode:	11
Remote Monitoring and Control:	11
Remote Monitoring and Control: Using Internet Browser.....	12
BULLDOG PLUS MONITOR OPERATIONS	14
Top Layer Buttons	14
Bulldog Monitor Main Menu	15
SYSTEM	16
Login	16
Monitor Screen	17
Font	17
Window	17
Close Monitor.....	18
CONFIGURATION.....	19
Configuration Window.....	19
DEVICES	21
Modem.....	錯誤! 尚未定義書籤。
Notification Users -- Pager List	21
Notification Users -- e-mail.....	21
Notify Users -- Network Broadcast.....	21
Color	22
Close	22
UPS	23
UPS Property.....	23
Attached Devices.....	23
Log Management:.....	24
Schedule.....	24
Action.....	25
Action - Shutdown:	26



Action - Logging:.....	26
Action - Broadcasting:	27
Action - Paging:	27
Action- Command:.....	27
Action - Alarm:	27
Action - e-mail:.....	27
Action - SNMP Trap:.....	27
Action - Receptacle Control:	28
Stop All Action	28
Voltage Sensitivity	28
Transfer Voltage	28
ADVANCED UPS PROPERTY.....	29
NETWORK	30
Set Password.....	30
Choose Master/Slave	30
Wake On LAN.....	31
SNMP	32
SNMP Trap Number:	33
HTTP	34
CONTROL	35
Shutdown Now.....	35
Cancel Shutdown.....	35
Turn Receptacle Relay On.....	36
Turn Receptacle Relay Off.....	36
UPS Audible Alarm On	36
UPS Audible Alarm Off	36
10 Seconds Test.....	36
Deep Battery Test.....	36
Cancel Test.....	36
VIEW.....	37
Meters.....	37
Event Log	37
History Graph.....	38
History Data	39
Auto Save	39
Remote Hosts.....	40
BOTTOM LAYER BUTTONS	41
Main.....	41



UPS Tree.....	42
Time.....	42
Status	42
Diagram	42
Scroll.....	42
Outlet	42
Network	42
SERVICE AND SUPPORT	43



Introduction

Congratulations on your purchase of Bulldog Plus to manage your Uninterruptible Power Supply (UPS). Bulldog Plus is designed to provide end users the ability to take proactive steps to protect their equipment from power related damages. Bulldog Plus allows for automatic shutdowns, scheduled shutdowns and a variety of other features that help you manage your system and its peripheral components.

Bulldog Plus provides detailed information about the UPS and its protected equipment. It is easy to install and program, yet has the necessary features to handle all of one's power requirements. Included is the capability for network management protocol (SNMP and DMI). Bulldog Plus will disseminate UPS information into SNMP protocol and project it to the appropriate Network Management Station (NMS), such as HP OpenView. To make use of resources on the Internet, Bulldog Plus also supports HTTP protocol. This enables end-users to monitor their UPS anywhere, anytime, by simply utilizing their web browser.

Bulldog Plus runs in the background as a Windows service, and communicates with the UPS in order to ensure that your computer and attached components are protected from any power problems.

Bulldog Plus features:

1. Graceful operating system shutdown
2. Scheduled tests, shutdown/restarts of the UPS, turn on/off receptacles
3. Flexible events
4. Notification: Pager, e-mail and audible alarm, network broadcasting and SNMP
5. Real-time values of voltage, current, frequency and loading...
6. Historical data & graph
7. Network monitoring
8. Multi-computer shutdown/restart
9. Support Simple Network Management Protocol (SNMP)
10. Support Desktop Management Interface (DMI)
11. Support HTTP, remote monitor and control using Internet browser
12. Support Universal Serial Bus (USB)
13. Multi-lingual menus



Bulldog Plus Installation

Bulldog Plus Setup:

1. Place the Bulldog CD in your CD-ROM device and execute the setup.exe to run the setup program.
2. Check the communication type of your UPS. If you select the USB option you must have connected the UPS to the computer and install the HID driver.
3. During the installation, the following dialog gives you 5 options:
 - Program File: Files contain Bulldog Service, Bulldog Monitor and this on-line help.
 - Audio Files: Some .wav files. These files will be played to notify you when power event occurs.
 - HTTP Files: Bulldog Plus HTTP DLL file and web page files.
 - SNMP Files: Bulldog Plus SNMP DLL file.
 - DMI Files: Bulldog Plus DMI DLL file and MIF file.
4. After finishing the installation, the setup process will create a Bulldog Plus association.
5. The Bulldog Plus software is comprised of two modules:
 - An UPS Monitoring Module (Bulldog Service), which runs in the background as a Windows NT Service and communicates to the UPS.
 - An User Interface Module (Bulldog Monitor), which enables you to control and configure Bulldog Plus through the drop down menus and dialog boxes. It also allows you to monitor the UPS through the Main Screen.

Setup: To modify, repair or remove Bulldog Plus from your hard disk.

Help: Bulldog Plus on-line help.

Bulldog Monitor: User interface, used to monitor and configure your UPS.

Bulldog Service: Bulldog Plus service program, used to communicate with your UPS.



Bulldog Plus Service

Belkin Bulldog Service runs in the background as a Windows NT Service when the system initiates. You can also run Bulldog Service manually by selecting the Start Menu- Program Files - Belkin Bulldog - Bulldog Service. Once Bulldog Service starts there is a Bulldog Service icon located on the system tray to indicate UPS status.

1. Normal




Normal

2. UPS Disconnect, cannot get any information from UPS.




UPS Disconnect

3. Power Failed! The UPS is operating on battery power.




Power Failed!

4. UPS Bypass Active!




Bypass

Moving your mouse over the Bulldog Plus icon in the system tray and click the right button to pop up the following menu




- Show Countdown: **Belkin Bulldog** displays the countdown time (time to shutdown/suspend the operating system) window to remind the user that the operating system will shutdown or suspend in the displayed time. This function lets the user know clearly how much time is left to shutdown/suspend the computer when power fails. The operating system shutdown time can be adjusted from the Action menu





- Monitor: Run the Bulldog Plus user interface.
- Configuration: Displays the configuration window, allows you to change the UPS parameters.
- Meters: Shows UPS real-time meters.
- Program Stop: If this item marked Bulldog Plus stopped. Unmark it and the program will resume.

Once a power event has occurred, Bulldog Plus will pop up a broadcast dialog box to inform user what happened to UPS.




Bulldog Plus Monitor

Bulldog Monitor enables you to control and configure Bulldog Plus through drop down menus and dialog boxes. It also allows you to monitor the UPS through the Main Screen. It is not necessary for Bulldog Monitor to reside in your computer's memory, the execution depends on the user's requirement. This can save precious system resources.

After finishing the Bulldog Plus installation, Bulldog Service automatically loads into memory and runs once the Windows operating system starts up. There is a Bulldog Plus icon that lies in the system tray to indicate current UPS status.

To run the Bulldog Monitor, moves the mouse cursor over the Bulldog Plus icon and double-click to launch Bulldog Monitor, or click the right button to pop up the menu:



Then select Monitor to run the program. You can also launch Bulldog Monitor without running Bulldog Service, select Bulldog Monitor from Program Files - Bulldog Plus menu.



Bulldog Monitor Main Screen:

BELKIN BULLDOG Plus Monitor

System Control View Wizard Help

Configure Meters Event Log History

Host Selection: Local=tnsofzcm 172.16.176.141 Model=BU100XR 2000 OS=Windows 98

UPS Health: ● www.belkin.com

UPS Type: **On-Line**

UPS Model: **BU100XR 2000**

Firmware Version: **1.0**

Host Name: **tnsofzcm**

Rating VA: **1000VA**

Rating Input Volt: **110V**

Rating Output Volt: **110V**

Rating Battery Volt: **41V**

Rating Input Freq: **60Hz**

Test Result: **No Test Performed**

AC Source: **Normal**

Battery Status: **Normal**

Battery Level: **100%**

Loading Level: **19%**

Input Voltage1: 118.8V

Output Voltage1: 110V

12/05/2001 13:55:26 <UPS communication established!>

Main Tree Time Status Diagram Scroll Receptacle Network




Networking

BULLDOG Plus software is comprised of two modules: **BULLDOG Service** and **BULLDOG Monitor**. You may run both the programs in a computer to monitor your localized UPS or run the programs in two different computers.

Operation Mode:

BULLDOG Service can operate in "Master" Mode (which allows BULLDOG to send commands to its connected UPS) in "Serial Slave" mode (which listens to its connected UPS) or in "Networking Slave" mode (which obtains the UPS information from Master via the network). If two or more computers are communicating with a single UPS, only one of these computers should be in Master mode; the others should be in Slave mode to prevent them from sending contradictory commands.




When a power event occurs, the Master gets the information then transmits it to Slave(s). Each BULLDOG Service executes different "Actions"(FlexEvent) so that the system manager can configure different strategies into each different computer. For example: When a power failure occurs, the file server and mail server won't shutdown until the UPS battery is low, but other less important workstations execute shutdown after 5 minutes, and the initial workstations shutdown after 10 minutes. Shutting down workstations preserves more battery power for your mission critical network servers.


Remote Monitoring and Control:

Bulldog Monitor has the ability to monitor Local hosts and Remote hosts.






You can run only Bulldog Monitor without running Bulldog Service. Bulldog Monitor will search hosts in the LAN(Local Area Network) which runs Bulldog Service in the combo box. Click on the Host Selection combo box to list the searched hosts in the LAN. Select one, then Bulldog Monitor will connect to the selected host.



If the host is located on the Internet, you can also input the remote host IP address from the View Menu- Remote Hosts menu shows the hosts you can establish connections with.



Remote Monitoring and Control: Using Internet Browser.

Another way to remote monitor Bulldog Service is by using the Internet Browser. Launch the Microsoft Internet Explorer or Netscape



Communicator, type the IP address in the URL and press enter. You


Status: UPS current status (update every 30 seconds)	
<input type="radio"/> UPS Comm Disconnect	<input type="radio"/> UPS System Off
<input checked="" type="radio"/> Buzzer Alarm	<input type="radio"/> Output Bad
<input type="radio"/> AC Fail	<input type="radio"/> Output Off
<input type="radio"/> Battery Low	<input type="radio"/> Fan Failure
<input type="radio"/> Battery Depleted	<input type="radio"/> Fuse Break
<input type="radio"/> Battery Need Replace	<input type="radio"/> Inverter Bad
<input type="radio"/> Test In Progress	<input type="radio"/> Charger Bad
<input type="radio"/> Overload	<input type="radio"/> Bypass Bad
<input type="radio"/> Overheat	<input type="radio"/> Awaiting Power
<input type="radio"/> UPS Fault	<input type="radio"/> Economic Mode

will then be able to see the UPS information. You can change the network port number to prevent conflict with other WEB server programs. If the port number isn't 80 you have to type URL like this: `http://172.16.176.141:2000` where 2000 is the port number you assigned.



Bulldog Plus Monitor Operations

The Main Screen has 7 areas that present information on the operating status of your UPS. These areas are discussed in the following sections.



Host Selection: Press the combo box to select hosts that runs Bulldog Plus in the LAN. Users can monitor or control the UPS remotely (password is needed).

Connection Indication: The logo will rotate while the communication between Bulldog Monitor and Bulldog Service is established.

Information Display: Press Bottom Layer Buttons to change the information that is displayed in this area.

Recent Event Log: Preserve last 10 event logs in the combo box, click on the combo box to pull down and view the logs.

Top Layer Buttons

These buttons are used to increase the speed of your operation, refer to the dialog boxes in the menu.



Configuration: Same as the System-> Configuration in the menu.

Meters: Same as the View-> Meters in the menu.



Event Log: Same as the View-> Event Log in the menu.

History Graph: Same as the View-> History Graph in the menu.

Bulldog Monitor Main Menu

The Main Screen has a menu bar at the top with 5 main options:



1. System: This menu allows you to set the Bulldog Plus and computer parameters.
2. Control: This menu allows you to set UPS buzzer, outlet, and test.
3. View: The View menu allows you to see the real-time values and history event or history data.
4. Wizard: Directs users to configure the most frequent use of settings, the wizard guides users step-by-step to finish their configuration.
5. Help: The Help menu allows you to access the online help system.



System

The system menu allows you to configure the UPS and the monitoring screen parameters. When you select the System menu from Main Menu bar, a drop down menu appears offering you the following menu options:



Login: Used for Remote Monitor. User must enter the password verification before he can control or configure the UPS.

Configuration: The Configuration menu allows you to tailor various Bulldog Plus parameters.


Monitor Screen: Allows you to change displayed item in the Scroll Screen of Information Display Area.

Font: Sets the font size. Bulldog Plus will resize the window automatically.

Window: This menu allows you to change the displayed items in the Information Display Area. The items in the menu refer to each button in the Bottom Layer Buttons.

Close Monitor: Stops Bulldog Monitor.

Login



When attempting to use Bulldog Monitor as a Remote Monitor (connect to different host) you have to enter the password for verification if you want to do such tasks as configurations, or to control the UPS.

Otherwise, you can only view the UPS information.

If user runs Bulldog Service and Bulldog Monitor on the same computer, you can perform such configurations or control the UPS without the




password.

To change your password, please choose the Set Password option from Configure - Network menu

Monitor Screen

This dialog box allows you to change displayed items in the Scroll screen of the Information Display Area



Language: Choose a language that suits your operating system needs. Program will automatically replace the on-line help file and audio files to your selected preferences.

Meters: Press the Main button from the Bottom Layer Buttons, and you will see that there are two meters in the information area. You can change the displayed items of the two meters.

Scroll Window: Press the Scroll button from the Bottom Layer Buttons, and the scroll window will display the information in this area. This item allows you to change the display menu and its items.

Font

This menu allows you to change the font size of Bulldog Monitor window.

Window

This menu allows you to change the display items in the Information Display Area. The items in the menu refer to each button in the Bottom Layer Buttons.



Close Monitor

Close Bulldog Monitor and leave Bulldog Service running.



Configuration



The Configuration Screen has a menu bar at the top with three main options:

Devices: This menu allows you to configure the modem, pager and e-mail applications.

UPS: The UPS menu allows you to plan and set the UPS schedule or perform the Action...

Network: This menu allows you to choose the Master/Slave settings or configure SNMP, HTTP functions.

Configuration Window

UPS Communication Port: COM1, ... COM4, USB.

Next UPS Test Date/Time: The date of the next user-initiated UPS self test. Setting from System->Configuration->UPS->Schedule.

Next UPS Shutdown Date/Time: This field displays the date of the next shutdown the computer and UPS. Setting from System->Configuration->UPS->Schedule.

Next UPS Restart Date/Time: The date of the next restart UPS. Setting from System->Configuration->UPS->Schedule.

Local Host IP: IP address of a computer, which runs Bulldog Monitor.



Bulldog Service Mode: Bulldog Service acts as a Master or Slave.

Remote Host IP: The host, which runs Bulldog Service. If Bulldog Monitor and Bulldog Service runs on the same computer and this field will be empty.



Notification Users -- Pager List

Program will set the modem to notify all via the pager numbers, which are listed in the pager list. You can input your pager number for your own notification purposes. For example: 060123456 is your pager number, each ',' tells modem to delay 2 seconds, delay time is for setting waiting period for the response signal, before proceeding to transmit to the displayed number 119. 119 will appear in your pager LCD.

To trigger the pager notification you must enable the Pager Action in the Action dialog box.

- a. Add: Add a new pager number.
- b. Modify: Modify the selected pager number.
- c. Delete: Delete the selected pager number.

Notification Users -- e-mail

You can also e-mail users through SMTP when power events occur.

To trigger the e-mail notification you must enable the e-mail Action in the Action dialog box.

- a. Add: Add a new user.
- b. Modify: Modify the selected user name.
- c. Delete: Delete the selected user.

Notify Users -- Network Broadcast

You can also broadcast information to users when a power event has occurred. The broadcast function is associated with Microsoft Messenger, so to send messages you must run under the Windows NT operating system.

To trigger the broadcasting notification you must enable the Broadcast Action in the Action dialog box.

- a. Domain: Enable this item to broadcast to all the users in the domain, otherwise Bulldog Plus will send messages to the hosts that users assign.
- b. Add: Add a new machine name.
- c. Modify: Modify the selected machine name.
- d. Delete: Delete the selected name.



Color

Used to change the screen color.


- a. Color Items: This area lets you select an item, which you want to change the color for. The right-top corner will display the current selected color.
- b. Change: Change the color you have selected.
- c. Default: Default setting.
- d. Exit: Close the dialog box.

Close

Close the Configuration window.



UPS



UPS Property

This dialog box allows you to configure the UPS COM port, battery replacement date, ... etc. Load Warning and Load Severity used to prevent UPS overload (see the UPS hardware user manual). In general, Load Warning will notify the user to reduce the UPS load, Load Severity will shutdown the computer to prevent overload.

- a. COM Port: COM1, ...COM4, USB.
- b. Load Warning: Load warning.
- c. Load Severity: User must reduce UPS load.
- d. Last Battery Replacement Date: Records the last battery replacement date.
- e. Next Battery Replacement Date: Displays the date of the next battery replacement, Bulldog Plus will notify the user to replace the battery.
- f. Host Name: Local host name.

Attached Devices

Allows the user to assign the attached device a name. When you're controlling the outlet, Bulldog Plus will let you know which devices you are controlling.

- a. Select an Outlet Group: Assigns an outlet group. Please look at the back panel carefully, some outlets may share one control relay, these outlets are called an outlet group. If you turn off the outlet group (for example: outlet1 and outlet2) then the UPS will stop power to the outlet group outlet1 and outlet2.
- b. Device Name: Assigns the attached devices a name, for example: Outlet Group1 is called Monitor for association with the monitor and Outlet



Group2 is called Computer for association with the CPU. These records can improve the efficiency of your management. Don't forget to press the Update button.

c. Update: Updates your change.

Log Management:

(Please consider the free space in your hard disk)

a. Maximum Event Log Entries: Always Bulldog Plus to preserve less than the assigned entries of event log.

b. Data Log Interval: Time designated for automatic saving of a record of UPS data.

c. Maximum Data Log Storage: It allows you to save how many months UPS data files you wish to keep.

Schedule

This function allows you to shutdown, restart, test and turn on/off outlets. You can schedule up to 6 events. Settings are based on day, week or month and up to a period of 2 years.

Choose the applicable schedule to set whether it be for:


a. One Time: This set schedule is applicable for a single day.

b. Daily: This set schedule is applicable for every day

c. Weekly: This set schedule is applicable for once a week period.

d. Monthly: This set schedule is applicable for once a month period.






Action

The action menu provides you with a list of events to choose from. The event and/or any combination of these actions can be selected from the Choose Event list box. Actions that are already enabled will show a check mark. To delay the actions, set the desired time for delay in the Delay combo box.





- a. Enable Auto-Save: Bulldog Plus will save opened files and close applications automatically when you enable this function.
- b. Choose Event: When you select one item in the list the action buttons will display current settings. Press button to do further configurations.
- c. Set Default: Sets all the actions to default values.
- d. Delay: The power event must stay within the delay time to trigger actions.

Action - Shutdown:

Shutdown/Hibernate/Suspend the operating system or shutdown UPS. If you select the shutdown item Bulldog Plus will execute or ignore the Auto-Save function depending on your selection in the Action dialog box. But if you select the “suspend” or “hibernate” item, the program will ignore the Auto-Save function.

The action of “shutdown”, “hibernate” or “suspend” are the same as if you select the Shutdown Option from the Windows Start menu.

Action - Logging:

Allows you to log events as well as modify the default logging message. You can see this message in the Event Log dialog box.



Action - Broadcasting:

Permits you to broadcast an event based on a set period of time. If you want to be notified once, set the time period to "0". However, if you want to be notified more than once, set the time period to a larger number. Each number corresponds to the number of times of notification.

Action - Paging:

Allows you to set the time period for paging intervals. If you want to be notified once, set the time period to "0". However, if you want to be notified more than once, set the time period to a larger number. Each number corresponds to the number of times of notification.

Action- Command:

Permits you to execute command files and set a period of time to delay its activation. To test this function, you can click the Test button. To enable or disable this action, mark the Enable Command check box.

Action - Alarm:

Permits you to send out audible alarm instead of a broadcast message. There are two alarms to select from - Buzzer and Audio. If you choose Audio, the Bulldog Plus requires a ".wav" file to emit the alarm. You can browse your system for other ".wav" files by clicking on the Browse button. If you want to be notified once, set the time period to "0". However, if you want to be notified more than once, set the time period to a larger number. Each number corresponds to the number of times of notification.

Action - e-mail:

Permits you to send e-mails through SMTP. If you want to be notified once, set the time period to "0". However if you want to be notified more than once, set the time period to a larger number. Each number corresponds to the number of times of notification. You can edit the user list by clicking the Edit list button, and add, modify or delete any user name in the list. To enable or disable this action, mark the Enable e-mail check box.

Action - SNMP Trap:

Lets you send a SNMP trap when the relative power event occurs. To enable or disable this action, mark the Enable SNMP Trap check box.



You also need to specify the SNMP Trap target hosts and community string, please see the SNMP dialog box in the Network menu.

Action - Receptacle Control:

Allows you to control the Receptacle Relay on or off. Each Receptacle Relay may control not only one outlet, please see the rear panel of your UPS or the UPS hardware user's manual.

Stop All Action

Clicking on this, terminates all the actions immediately.

Voltage Sensitivity

Adjusts the UPS voltage sensitivity.


Transfer Voltage

Changes the low transfer voltage and high transfer voltage. This function lets your UPS adjust to the local power environment.

- a. Low Transfer Voltage: When utility power voltage drops lower than the assigned value the UPS will switch to backup mode. The output power is supplied from the battery.
- b. High Transfer Voltage: When utility power voltage rises higher than the assigned value, the UPS will switch to backup mode. The output power is supplied from the battery.



Advanced UPS Property




If your UPS doesn't support this function, the item will be displayed as gray and the user cannot select this item.

Enable Wakeup Computer: If your computer architecture is compatible to ATX and the BIOS supports RS-232(RI) Wakeup function. You should enable this item to make the Schedule work correctly.

Enable Resume Computer: Be sure the BIOS supports RS-232(RI) Wakeup function. When Bulldog Plus suspends the computer and the UPS detects the change of power status, the UPS will resume the computer to its prior operating status and let Bulldog Plus notify users.

Enable Power Fail, Auto-Reboot: The time-line describes below,



If you enable this function, the UPS will reboot to restart the computer otherwise, it goes back to its normal state.

Enable Economic Mode: Switches to UPS economic mode.

UPS Periodic Auto-Test: Daily, weekly, biweekly and monthly. UPS starts the test procedure automatically when it reaches the test time.



Network



Set Password

Sets the Bulldog Service password.

Choose Master/Slave

Please refer to the BULLDOG Service operation mode. If the computer connects to UPS directly (with RS-232 or USB) and can send commands to its connected UPS then the BULLDOG Service acts as a "Master". If it connects to UPS directly (with RS-232 or USB) but only listens to UPS then it is a "Serial Slave". If the computer is powered by the UPS, but obtains the UPS information from Master via TCP/IP network then it is a "Networking Slave". When BULLDOG Service is a Networking Slave you must assign the Master IP address so that the Networking Slave can connect to the Master and obtain the UPS information.


- a. Master: Configures the BULLDOG Service to be a Master.
- b. Serial Slave: Configures the BULLDOG Service to be a Serial Slave.
- c. Networking Slave: Configures the BULLDOG Service to be a Networking Slave.
- d. Master IP Address: When BULLDOG Service is a Networking Slave you must assign the Master IP address so that the Slave can connect to the Master host and obtain the UPS information.





Wake On LAN

To wake up the remote host, Bulldog Plus sends notification through the network. You must provide the IP address and the network hardware address of the remote host. In Windows98, you can execute the "ipconfig /All" command under the MS-DOS prompt to obtain the network cards physical address of the local host. Or, input the "arp -a" command to see the remote host's physical address. Your network card must support the remote wakeup feature and this function should be enabled.



a Bulldog Plus Resume The Computer From Suspend Mode: Bulldog Plus will reinstate the computer into normal mode, and the program will awaken the remote hosts once the actions have been enabled.

b. Each Time Bulldog Plus Startup: Program will wake up the remote hosts which are enabled when Bulldog Plus starts and is connected to the UPS.



SNMP

If you are using a Windows 95/98/Me operating system, you can configure the SNMP parameters directly from the Bulldog Plus:

Select the Accept SNMP packet from any hosts, Bulldog Plus will accept all the requested commands and set commands. When you select the Accept SNMP packet from the following hosts, Bulldog Plus receives information only from the hosts that you assigned. Once a power event has occurred and the user enables the SNMP Trap in the Action dialog box, Bulldog Plus will send the SNMP trap to the hosts that are listed in the Trap Target list box. To add, modify or delete the host, click on its respective command button.

The screenshot shows the 'SNMP' configuration dialog box. It features a title bar with the text 'SNMP' and a close button. The main area contains three text input fields: 'Port Number' (value: 161), 'System Contact' (value: Jesse), and 'System Name' (value: Power UPS). To the right of these fields are 'OK' and 'Cancel' buttons. Below the input fields are two radio button options: 'Accept SNMP packet from any hosts' (selected) and 'Accept SNMP packet from the following hosts'. The second option is followed by an empty list box with 'Add...', 'Modify...', and 'Delete' buttons below it. At the bottom is a 'Trap Target' section with a list box containing '172.16.176.141 public' and '172.16.176.142 private' (the second is selected), with 'Add...', 'Modify...', and 'Delete' buttons below it.

If you are using a Windows NT,2000 or Windows XP operating system, you must install the SNMP Service and configure the SNMP parameters from your operating system:

Bulldog Plus will ignore the values that were set in the SNMP dialog box. To change the parameters of SNMP function, you should install the SNMP Service in the Network option. Select the SNMP Service from the Network option in the Control Panel and click the Property button to do your changes.



SNMP Trap Number:


Variable	Trap No.	Description
dupsCommunicationLost	1	SEVER: Communication with the UPS failed
dupsCommunicationEstablished	2	INFORMATION: Communication with the UPS reestablished
dupsPowerFail	3	WARNING: Power failed! The UPS is operating on battery power
dupsPowerRestored	4	INFORMATION: Power restored! The utility power restored
dupsLowBattery	5	SEVER: The UPS batteries are low and will soon be exhausted
dupsReturnFromLowBattery	6	INFORMATION: The UPS has returned from a low battery condition
dupsLoadWarning	7	INFORMATION: Loading percent of the UPS over the Load Warning value
dupsNoLongerLoadWarning	8	INFORMATION: Returned from Load Warning condition
dupsLoadSeverity	9	Warning: Loading percent of the UPS over the Load Severity value
dupsNoLongerLoadSeverity	10	INFORMATION: Returned from Load Severity condition
dupsLoadOnBypass	11	WARNING: The UPS loads on bypass
dupsNoLongerLoadOnBypass	12	INFORMATION: The UPS is not on bypass mod
dupsUPSFault	13	SEVER: A general fault caused in the UPS
dupsBatteryGroundFault	14	SEVER: The UPS battery ground fault
dupsNoLongerBatteryFault	15	INFORMATION: The UPS recovered from battery ground fault
dupsTestInProgress	16	INFORMATION: The UPS test in progress
dupsBatteryTestFail	17	SEVER: The UPS test in progress
dupsFuseFailure	18	SEVER: The UPS fuse failed
dupsFuseRecovered	19	INFORMATION: The UPS fuse recovered
dupsOutputOverload	20	SEVER: The UPS overload
dupsNoLongerOverload	21	INFORMATION: Recovered from UPS overload
dupsOutputOverCurrent	22	SEVER: The UPS output is over current
dupsNoLongerOutputOverCurrent	23	INFORMATION: Recovered from UPS over current
dupsInverterAbnormal	24	SEVER: The UPS inverter is operating abnormally
dupsInverterRecovered	25	SEVER: Recovered from UPS inverter abnormal state
dupsRectifierAbnormal	26	SEVER: The UPS rectifier is operating abnormally
dupsRectifierRecovered	27	INFORMATION: The UPS recovered from abnormal state
dupsReserveAbnormal	28	SEVER: The UPS rectifier is operating abnormally
dupsReserveRecovered	29	INFORMATION: The UPS rectifier is now operating normally
dupsLoadOnReserve	30	INFORMATION: The UPS load on reserve
dupsNoLongerLoadOnReserve	31	INFORMATION: The UPS no longer load on reserve
dupsEnvOverTemperature	32	WARNING: The environment is over normal temperature
DupsNoLongerEnvOverTemperature	33	INFORMATION: The environment recovered from abnormal temperatures



DupsEnvOverHumidity	34	WARNING: The environment over normal humidity
DupsNoLongerEnvOverHumidity	35	INFORMATION: The environment recovered from abnormal humidity

HTTP


Bulldog Plus supports WEB Server for remote management and to obtain the UPS information. Users can use IE or Communicator to connect with Bulldog Service. Even your computer doesn't have Bulldog Plus installed you can monitor and control your UPS via the network.




- a. Enable HTTP: Enable or disable the feature of Web service.
- b. HTTP Root: The HTTP root path. All the html and gif files will be located here.
- c. Port Number: The default port number is 80 but if there is already one WEB server running you can change Bulldog Service HTTP port number to a different number. At the Internet Browser you can input `http://172.16.176.141:2000` in the URL where 2000 is the assigned port number.



Control



Shutdown Now



This command will execute the shutdown procedure at once.

- Restart:** This function lets you restart the UPS automatically after being shutdown. To start the UPS for the next schedule, mark the Restart check box.
- Shutdown OS and UPS:** Use this function to shutdown both the OS and UPS.
- SHUTDOWN OS Only:** Use this function to shutdown OS only.
- SUSPEND OS Only:** Use this function to suspend your operating system.
- HIBERNATE OS Only:** Use this function to hibernate your operating system.

Cancel Shutdown

This menu enables you to terminate the current shutdown procedure.



Turn Receptacle Relay On

Turns the selected receptacle relay on. Each Receptacle Relay may control more than one outlet, please see the rear panel of your UPS or the UPS hardware user's manual.

- a. Select a Receptacle Relay: Selects a receptacle relay.
- b. Delay: Set the delay time to turn on the receptacle relay.
- c. On: Executes the stated command.

Turn Receptacle Relay Off

Turns the receptacle relay off. Each Receptacle Relay may control more than one outlet, please see the rear panel of your UPS or the UPS hardware user's manual.

- a. Select a Receptacle Relay: Selects a receptacle relay.
- b. Delay: Set the delay time to turn off the outlet group.
- c. Off: Executes the turn off command.

UPS Audible Alarm On

Enables the UPS buzzer. On the Bottom Layer Buttons press the Status button to get the UPS buzzer status.

UPS Audible Alarm Off

Mutes UPS buzzer alarm.

10 Seconds Test

UPS switches to backup mode and the output power is supplied by the battery for 10 seconds.

Deep Battery Test

UPS switches to backup mode and output power is supplied by the battery until the battery is low.

Cancel Test

This menu allows you to stop the test immediately.




View



Meters

Bulldog Plus supports up to 12 meters of real-time values. Each meter has the ability to display all of the UPS values. Selecting different items from the Selection dialog box will display the selected item value.




- 2,4,6,8,12: Displays meter number.
- Selection: Assigns each meter to a different UPS item value.
- Close: Closes the meter window.

Event Log

This menu offers you the possibility of viewing past events.






- a. Print: Prints the event log.
- b. Exit: Closes event log dialog box.

History Graph

Clicking on the History Graph opens a dialog box that contains information about the UPS data in graphical format. This information is available only if there is an accumulation of data. You can select the month and year you want to view.



- a. Horizontal Scale: Selects the time scale.
- b. Vertical Scale: Selects the value scale.
- c. Select Month: Displays the UPS data for the month, which you want to see.
- d. Draw Item1(Blue): Displays the UPS item value by a blue line.
- e. Draw Item2(Red): Displays the UPS item value by a red line.
- f. Update: Updates the graph.
- g. Print: Exports the graph to a printer.
- h. Exit: Closes the history graph dialog box.

History Data

Clicking on the History Data opens a dialog box that contains information about UPS data in list format. This information is available only if there is an accumulation of data. You can select the month and year you want to view.

	Date	Time	Battery Voltage	Battery Current	Battery Level	Input Frequency
1	02-25-2002	16:50	27.2		100.0	60.0
2	02-26-2002	14:30	27.2		100.0	60.0
3	02-26-2002	14:31	27.2		100.0	60.0
4	02-26-2002	14:32	27.2		100.0	60.1
5	02-26-2002	14:33	27.2		100.0	60.0
6	02-26-2002	14:34	27.2		100.0	60.0
7	02-26-2002	14:35	27.2		100.0	59.9
8	02-26-2002	14:36	27.2		100.0	60.0
9	02-26-2002	14:37	27.2		100.0	60.0
10	02-26-2002	14:38	27.2		100.0	60.0
11	02-26-2002	14:39	27.2		100.0	60.0
12	02-26-2002	14:40	27.2		100.0	60.0

- a. Select Month: Displays the UPS data in the month, which you want to see.
- b. Update: Updates the list.
- c. Save As: Saves the data in the list format to the file that you assigned.
- d. Print: Exports the list data to a printer.
- e. Exit: Closes the history data dialog box.

Auto Save

When certain power events occur, Bulldog Plus will save open files and close applications before shutting down the operating system. If these saved files are untitled, Bulldog Plus will assign file names for them and




put the files in temporary directory. This dialog box will tell you which files were saved by Bulldog Plus.

- a. Program Title: The application's title name.
- b. Auto-Save File Name: Bulldog Plus names the file for you.
- c. Clear: Clear this record.

Remote Hosts

Detects the hosts, which are running the Bulldog Service in the LAN. You can also type in the IP address and connect to the WAN.




- a. Search Result: The hosts will be listed in the Search Result list box. Select the host you want to connect to and press the Connect button to establish the connection.
- b. Connects to this IP address: Bulldog Plus will connect to the IP address, which you type in.
- c. Connect: Establish the network connection.



Bottom Layer Buttons

Each button shows the respective information in the Information Area



Main: General Information about the UPS.

Tree: There are 2 sub-trees in the Bulldog Plus tree: System and UPS. The system tree is for host information and the status of Master/Slave connection, the UPS tree is for all other UPS information.

Time: Displays the time for all schedules, battery replacement date and countdown time.

Status: UPS status.

Diagram: Indicates the UPS current flow.

Scroll: UPS data graph.

Outlet: Displays outlet status. (If your UPS cannot control the outlet then this button disappears)

Network: Indicates the connection of Master/Slave, Bulldog Monitor and Bulldog Service.

Main

UPS Health: 3 levels: Green, yellow and red.

UPS Type: On line, off line, line interactive or 3 phase on line.

UPS Model: The UPS model, which is being monitored by Bulldog Plus.

Firmware Version: Indicating the version status of the UPS internal code.

Host Name: The host, which runs Bulldog Plus.

Rating VA: The UPS rating VA.

Rating Input Voltage: The UPS rating input voltage.

Rating Current: The UPS rating current.

Rating Battery Voltage: The UPS rating battery voltage.

Rating Input Frequency: The UPS rating input frequency.

Test Result: Results of the last self-test.

AC Source: Normal, battery or bypass.

Battery Status: The status of battery.

Battery Level: Percentage of battery level.

Loading: Output loading percentage.

Bulldog Plus with the ability to change the display item of the meters, the



referred menu item: System-> Main Screen.

UPS Tree

System: System tree for host information and the connection of Master/Slave.

UPS: UPS tree for all of the UPS information.

Time

Last Battery Replacement Date: To change the date of last battery replacement in the System-> Configuration UPS->UPS Property.

Next Battery Replacement Date: To change the date of next battery replacement in the System-> Configuration UPS->UPS Property.

Next 10 seconds Test Time: System-> Configuration UPS-> Schedule.

Next Deep Test Time: System-> Configuration UPS-> Schedule.

Next Shutdown UPS Time: system->Configuration UPS-> Schedule.

Next Restart UPS Time: System-> Configuration UPS-> Schedule.

Status

Shows all of the UPS statuses, red light indicates this event happened.

Diagram

Input and output power flow of UPS.

Scroll

Records the most recent UPS data information. You can change the displayed item from System->Main Screen.

Outlet

Displays the UPS outlet status (If your UPS cannot control the outlet this button disappears).

Status: Identifies the current outlet status: Normal or shut.

Next Turn Off Time: System->Configuration->UPS->Schedule

Next Turn On time: System->Configuration->UPS->Schedule

Network

Displays all the Bulldog Services searched in the LAN.



Service and Support

Corporate Headquarters

Belkin Corporation
501 West Walnut Street
Compton • CA • 90220-5221 • USA
Tel: 310.898.1100
Fax: 310.898.1111

Customer Service/Sales:
800.2BELKIN
800.223.5546

Technical Support:
310.898.1100 ext. 2263
800.223.5546 ext. 2263
Fax: 310.604.2089
techsupp@belkin.com
belkin.com/support/tech

United Kingdom

Belkin Components, Ltd.
Express Business Park
Shipton Way • Rushden • NN10 6GL
United Kingdom
Tel: +44 (0) 1933 35 2000
Fax: +44 (0) 1933 31 2000

France

Belkin SAS Components
5 rue du Petit Robinson
78 350 Jouy en Josas • France
Tel: +33 (0) 1 34 58 14 00
Fax: +33 (0) 1 39 46 62 89

Germany

Belkin Components GmbH
Hanebergstrasse 2



80637 • München • Germany

Tel: +49 (0) 89 143405 0

Fax: +49 (0) 89 143405 100

The Netherlands

Belkin Components B.V.

Starparc Building • Boeing Avenue 333

1119 PH Schiphol-Rijk • The Netherlands

Tel: +31 (0) 20 654 7300

Fax: +31 (0) 20 654 7349

European Customer Service/Sales:

00 800 223 55 460

eurosales@belkin.com

European Tech Support:

00 800 223 55 460

eurosupport@belkin.com

Australia

Belkin, Ltd.

7 Bowen Crescent • West Gosford • NSW 2250 Australia

Tel: +61 (0) 2 4372 8600

Fax: +61 (0) 2 4372 8603

Tech Support:

Australia Toll Free 1800 666 040

New Zealand Toll Free 0800 441 913

Singapore Toll Free 800 6161 790

belkin.com/anz

China

Belkin Shanghai Representative Office

Suite 31 • 39/F • Plaza 66

1266 Nanjing West Road

Shanghai • 200040 • China

Tel: 8621-62881747

Fax: 8621-62881748



Customer Service/Sales:
china@belkin.com

Tech Support:
800-820-5816

